



# 701 Ultrasonic Point Level Switch

## General Instructions

The Ultrasonic Point Level Switch energizes/de-energizes a DPDT relay to indicate liquid presence/absence within the sensor cavity. Two piezoelectric crystals face each other across the cavity. The transmitter crystal sends an ultrasonic signal to the receiver crystal. When liquid fills the cavity, the receiver crystal detects a strong signal because liquids are good conductors of ultrasonic waves. When the cavity is empty, the receiver crystal detects a weaker signal because air is a poor conductor of ultrasonic waves.



**NOTE: If you suspect that a product is defective, contact the factory or the SOR® Representative in your area for a return authorization number (RMA). This product should only be installed by trained and competent personnel.**


### Table of Contents

PC Board Arrangement.....	2
Sensor Installation .....	2-3
Remote Cable Connection .....	4-5
Electrical Connection.....	5-6
Failsafe Switch.....	6
Sensor Test Procedure .....	7
Time Delay.....	7
Installation Drawings .....	8-9
Dimensions .....	10
Troubleshooting .....	11
Field Replacement - PC Board.....	11
Replacement Fuses .....	12
Spare Parts .....	12

*Design and specifications are subject to change without notice.*

*For latest revision, go to [www.sorinc.com](http://www.sorinc.com)*

## PC Board Arrangement



## Sensor Installation (Applies to all models)

Series 701 Ultrasonic Level Sensors can be mounted by inserting the sensor through a fitting in a vessel, or the sensor may be suspended over an open sump or basin. Keep the sensor cavity out of the direct flow of liquid fill to prevent false readings. Install a baffle to divert liquid flow if necessary.



**DO NOT weld any part of this instrument.**


### Tank or Vessel

Make sure that the sensor can be fully inserted and tightened without interference from obstructions inside the tank or vessel.

Apply suitable sealant to the process connection to prevent process leakage.

Use an open end wrench to tighten the sensor into the process connection.

Do not use the sensor housing as a handle to tighten the process connection.



## Horizontal Mounting



When tightened securely, the sensor cavity must be positioned vertically for optimum drainage when process liquid level drops below the sensor cavity.

An alignment mark X stamped on a wrench flat (or on the dry face of a flange below the housing) shows sensor cavity orientation.

Optimum drainage occurs when the X mark is located at 6 or 12 o'clock.

Level is detected when the sensor cavity is filled with process liquid.

The sensor must project through a tank fitting so that the sensor cavity is at least 1" beyond the inner wall of the tank.



## Open Sump or Basin

Do not suspend the unit by rigid conduit installed in the electrical hub. When installing the unit over an open sump or basin use a suitable bracket to support the instrument.

***NOTE: The instrument must be positioned so that overflow does not flood the electrical housing.***


## Remote Cable Connection (Applies to remote units only - R Housing)



*Electrical power must be disconnected from explosion proof models before the cover is removed. Failure to do so could result in severe personal injury or substantial property damage.*


Conduit must be installed between the sensor base and the electronics housing to provide a raceway for sensor extension cables. The sensor base and the electronics housing are suitable for use in Class I Group C & D; Class II Groups E, F, & G; Division 1 & 2 Hazardous Locations. All conduit and fittings used for the installation must equal or exceed this rating to maintain the explosion proof integrity of the assembly.

Ensure that wiring conforms to all applicable local and national electrical codes and install unit(s) according to relevant national and local safety codes.



### Fishing the Sensor Extension Cables

Two sensor extension cables are supplied. Both ends of the cables are terminated and labeled at the factory.




Use care to avoid damaging the factory installed mini-phono connectors while fishing the sensor extension cables through the conduit. Pull cables from the sensor base so that the free ends follow the fish through the conduit.

Discharge the Sensor Temperature changes which occur during shipment may result in a small electrical charge inside the sensor crystals. This charge is harmless to humans, but may result in damage to the electronics if the sensor is plugged in before it is discharged. To discharge the sensor, touch a wire to each sensor connector so that the center conductor and outside shell make contact.

## Sensor Connections Inside Sensor Base

Inside the sensor base, a remote interconnect board rests in a plastic holder. Slide the interconnect board up. Attach the sensor coax connectors to the interconnect board as follows:

- 1 Connect one sensor cable to IN 1.
- 2 Connect the other sensor cable to IN 2.  
Attach the extension cables to the interconnect board as follows:
- 3 Connect cable A to OUT 1.
- 4 Connect cable T to OUT 2.  
Plug in Connections Inside Electronics Housing. Plug sensor extension cables onto the PC board as follows:



- 5 Connect cable A and cable T to the Sensor Lead Connections. See PC Board Arrangement on page 2 to locate Sensor Lead Connections.

OUT connections are located on the opposite side of the board from the IN connections. Do not use positions 3 and 4 to connect wires.

Tip-sensitive sensor connections are not sensitive to position. Sensor Lead Connection wires may be interchanged without affecting the performance of the instrument.

## Electrical Connection (Applies to all models)



***Electrical power must be disconnected from explosion proof models before the cover is removed. Failure to do so could result in severe personal injury or substantial property damage.***

A nine-position terminal strip provides connections for DPDT Liquid Level Relay Contacts, Line Power and Ground. Terminal positions are labeled on the green insulator card as shown on Page 6.

### A. Liquid Level Relay Contact Terminals

On units without OD, OF, or FS accessories, there is no fail-safe switch. The normal operation of the unit is fail-safe hi. When the sensor is dry, the relay is de-energized; the normally closed position (NC) and common (C) are in contact. When the sensor is wet, the relay is energized; the normally open position (NO) and common (C) are in contact.

On units with OD, OF, or FS accessories, there is a failsafe switch. The failsafe switch is located on the upper right hand corner of the circuit board with contact terminals facing away from you (see circuit board illustration on the front cover). Refer to Page 6 for switch options.

## B. Line Power Terminals


Terminals are provided for incoming power leads on the nine-position PC board terminal strip.

Supply voltage for each PC board is printed on the green insulator card. Make sure that the available line voltage matches device's power supply.

## C. Ground Terminals

The housing and the PC Board must be connected to ground. Ground (earth) screws are provided on the nine-position PC board terminal strip and on the housing floor.

If extra clearance is required for connection to the ground screw on the housing floor, the PC board can be removed and reinstalled according to Field Replacement—PC Board on page 11.



## Failsafe Switch (Models with OF, OD, or FS accessories only)

Failsafe Mode Switch Position	Sensor Condition	Liquid Level Relay Contact A Continuity Chart
 Relay energized on high level	Liquid above sensor 	 ■ NC1 C1 NO1 NO2 C2 NC2 ■ Relay Energized
	Liquid below sensor 	 ■ NC1 C1 NO1 NO2 C2 NC2 ■ Relay De-energized
 Relay energized on low level	Liquid above sensor 	 ■ NC1 C1 NO1 NO2 C2 NC2 ■ Relay De-energized
	Liquid below sensor 	 ■ NC1 C1 NO1 NO2 C2 NC2 ■ Relay Energized

## Sensor Test Procedure (Applies to all models)



*Units in Hazardous Locations - Prior to calibration, make sure that the work area is declassified before removing the explosion proof cover to calibrate the unit. Failure to do so could result in severe personal injury or substantial property damage.*

- ❶ Disconnect a sensor cable from the PC board. Measure capacitance across the two conductors of the sensor cable.
  - Capacitance from 2,000 to 3,000 pf indicates circuit is okay. Plug the sensor cable back into the PC board. Go to step 2.
  - Capacitance lower than 2,000 pf or higher than 3,000 pf indicates circuit is bad. Go to step 3.
- ❷ Repeat step 1 for the other sensor cable.
- ❸ A replacement sensor can be ordered from the factory or the SOR Representative in your area. Required order information: model and serial numbers stamped on the sensor nameplate.

## Time Delay (Models with OD or OF accessories only)

On and off delay timers are fixed to a customer specified constant. The timers are not field adjustable.

### On Delay Timer


On delay is an integral timer that starts when process liquid is detected in the sensor cavity. If the liquid level falls before the On timer completes its cycle, the timer resets to zero and waits for the sensor cavity to fill again. When the On timer completes its cycle, the Liquid Level Relay changes state to indicate liquid has filled the sensor. Failsafe switch (page 6) is included with the delay timer option.

### Off Delay Timer

Off delay is an integral timer that starts when the process liquid evacuates the sensor cavity. If the liquid level rises into the sensor cavity before the off timer completes its cycle, the timer resets to zero and waits for the liquid to fall again. When the off timer completes its cycle, the Liquid Level Relay changes state to indicate liquid has evacuated the sensor cavity. Failsafe switch (page 6) is included with the delay timer option.


# Installation Drawings

## CSA Probe/Electronics Combinations




# Installation Drawings

## FM Probe/Electronics Combinations



# Dimensions

Integral model with threaded process connection shown.



Linear = mm/inches

**Drawing 0390415**

Process Connection	*Add to Length
3/4" NPT(M)	Shown
1" NPT(M)	Add $\frac{8.0}{.313}$
1-1/2" NPT(M)	Add $\frac{9.5}{.375}$
2" NPT(M)	

## Troubleshooting

Symptom	Possible Causes	Solutions
No response to liquid level	No power to unit.	Restore power. Check fuse(s).
	Blown fuse.	Replace fuse(s). (See page 12.)
	One or both sensor cable(s) unplugged from PC board.	Replace sensor cable plug(s) according to the Field Replacement procedure. (See above.)
	Internal or external damage to sensor. Sensor damage can be verified using sensor test procedure. (See page 7.) If sensor tests okay, replace circuit board according to field replacement procedure. (below)	Replace entire instrument or contact factory for replacement sensor. The factory will request model and serial numbers to provide replacement sensor.

## Field Replacement - PC Board

Identical replacement printed circuit boards can be ordered by specifying the part number from the spare parts table on page 12.

De-energize all supply and control conductors that enter the housing. Failure to disconnect electrical power could result in severe personal injury and substantial plant damage from ignition of hazardous atmosphere.

- ❶ Remove the electronics housing cover.
- ❷ Note existing connections, then disconnect all conductors from the PC board terminal strip.
- ❸ Remove the two screws to release the PC board bracket from the housing.
- ❹ Slide the PC board straight up, then unplug the sensor cables from the PC board.
- ❺ Slide the old PC board completely out of the housing.
- ❻ Slide the new PC board into the PC board mounting slots.
- ❼ Discharge sensor crystals as shown on page 4. Failure to do so may damage the electronics.
- ❽ Plug the sensor cables into J1 and J2 connectors on the new PC board. The sensor will function properly regardless of orientation.
- ❾ Reinstall the two screws to secure the PC board bracket to the housing.
- ❿ Reconnect all conductors to the PC board terminal strips.
- ⓫ Replace the cover.
- ⓬ Restore power to supply and control circuits.

## Replacement Fuses

Replacement fuses may be ordered from SOR or electronic parts suppliers.

Please note that two fuses are required for 240VAC (P8) units and one fuse is required for 24VDC (P6) and 120VAC (P7) units.

Supplier	Part Number
SOR	2806-007
Wickman	19373-035-K
	19373-250MA-K
Schurter	MSF-250-034.6008

## Spare Parts

Model and Serial Numbers are necessary to ensure receipt of the proper replacement circuit board. To order the correct PC board for an instrument, find a match for the namplate model number in the left column below. Ignore characters which fall in a  space. Order a part number from the column to the right of the model number.

Model Number Contact the factory for the correct replacement board if the model number has FS, OD, or OF near the end of the model number.	Replacement PC Board Kit This kind includes PC mounting bracket and hardware. Do not use these numbers if your unit contains failsafe or time delays. Contact the factory for the appropriate part numbers.
701 <input type="checkbox"/> <input type="checkbox"/> -U-P6-C	5002-986
701 <input type="checkbox"/> <input type="checkbox"/> -U-P7-C	5002-987
701 <input type="checkbox"/> <input type="checkbox"/> -U-P8-C	5002-988



Printed in USA

sorinc.com

14685 West 105th Street, Lenexa, KS 66215 ■ 913-888-2630 ■ 800-676-6794 USA ■ Fax 913-888-0767